



Colorado Department of Labor and Employment
Division of Oil and Public Safety – Compliance Section
633 17th Street, Suite 500
Denver, CO 80202-3610

Phone: 303-378-1103
Fax: 303-318-8488
Email: cdle_oil_inspection@state.co.us
Web: www.colorado.gov/ops

LP-Gas Installation Application Requirements

The Division of Oil and Public Safety (OPS) must approve installation plans for all LP-Gas containers of more than 2000 gallons (single or aggregate), or any installation with a dispenser, prior to the beginning of installation. This includes installations at facilities where a container is being replaced by another container.

Complete the LP-Gas Installation Application that is available on the OPS website to submit your installation plan for approval.

The application must include a plot plan that indicates all of the following information:

- Lot dimensions
- Physical protection
- Distances from LPG tanks
- Points of transfer to:
 - Buildings
 - Roads
 - Railroads
 - Property lines
 - Overhead electrical lines
 - Vaporizers
 - Other flammable liquid storage tanks
 - Dispensers (gas, diesel, etc.)
 - Containment dikes.

(The point of transfer is the location where connections and disconnections are made or where LP-Gas is vented to the atmosphere in the course of transfer operations.)

You may send completed LP-Gas Installation Applications via email or postal mail as listed below.

Email to:
wayne.reinert@state.co.us

Mail to:
Colorado Division of Oil and Public Safety
633 17th Street, Suite 500
Denver, CO 80202-3610

Contact Scott Simmons at scott.simmons@state.co.us or 303-378-1103 if you have questions.