



Colorado Department of Labor and Employment
 Division of Oil and Public Safety – Compliance Section
 633 17th Street, Suite 500
 Denver, CO 80202-3610

Phone: 303-318-8525
 Email: cdle_oil_inspection@state.co.us
 Web: www.colorado.gov/ops

UST Monthly Compliance Inspection Checklist

(Revised 5/6/2019)

*If you answer "No" to any questions, you must complete the attached Repair Log.

General Information

Facility ID #:		Facility Name:		Number of Tanks:	
Facility Address:				City/State/ZIP:	
Contact Name:		Phone Number:		Review Starting Date:	Review Ending Date:

Tank Area*

		Inspection Dates:												
Area	Description	Area of Concern	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Spill Containment Bucket	Fill Lid	1. Are all fill lids present and in good condition?												
		2. Are fills correctly identified by color and located on the correct tank?												
	Spill Containment Bucket	3. Is the spill bucket free of dirt, trash, water and product?												
		4. Is the spill bucket in good condition and free of damage (no cracks, bulges or holes)?												
		5. Does the drain assembly work (if applicable)?												
	Fill Riser	6. Is the fill adaptor tight on the riser pipe?												
		7. Is the fill cap in place with a gasket and sealed tightly on the fill pipe?												
Overfill Valve	8. Is the overfill device free of obstructions?													
Tank Interior	Water Level	9. Does the tank contain less than ¼ inch of water? Note: If the water level is greater than ¼ inch, remove all water to extent possible.												

Area	Description	Area of Concern	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Vapor Recovery	Vapor Recovery Port	10. Is the vapor cap in place with a gasket and sealed tightly on the vent pipe?													
		11. Does the poppet of the vapor recovery adaptor seal tightly?													
		12. Are the vapor recovery lids painted orange?													
Dispensers*															
Area	Description	Area of Concern	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Dispenser-Hanging Hardware	Nozzles	13. Are the nozzles pressure-sensitive?													
		14. Are the nozzles in good condition and free of leaks?													
	Swivels	15. Are the swivels in good condition and free of leaks?													
	Hoses	16. Are the hoses in good condition and free of leaks?													
	Breakaway Connectors	17. Are the breakaway connectors in good condition and free of leaks?													
	Breakaway Hoses	18. Are the breakaway hoses in good condition and free of leaks?													
Leak Detection*															
Area	Description	Area of Concern	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Leak Detection	ATG Console	19. Does the ATG have power?													
		20. Does the ATG printer have paper and is it in working condition (If applicable)?													
		21. Do the liquid measurements and the ATG readings appear to be accurate?													
		22. Are the warning or alarm lights off?													
	Areas with Visible Piping	23. Are under dispenser areas, submersible turbine pump areas and piping transition areas free of leaks? <i>Note: This requires a visual inspection or electronic sensors in containment sumps.</i>													
	Mechanical Line-Leak Detection	24. Are dispensers operating at normal flow rates (not in slow-flow)?													
Daily Inventory	25. Are inventories reconciled daily and are the variances within the guideline set by the facility owner?														

